


Subtract – Metering Application



Oncor does not rely upon customer grounding for protection of its personnel – the 200 amp, self contained, meter base is the largest self contained meter base and provides the most protection for our personnel

The transocket, although it can have a higher amp rating, introduces more risk for our personnel, thus is **not** permitted in this type of application

Oncor will require a separate driven ground for Oncor's meter only – It will not be tied to any of customer's equipment

Oncor will require a disconnect device. Visit with the assigned Oncor Project Manager for more direction on its location

Oncor owns the meter only – customer owns and installs the meter base

SME – Metering Application

